



# EXPLOSION PROTECTION

## CERTIFICATE OF CONFORMITY

Cert NO.GYJ17.1390X

This is to certify that the product

Industrial HMI Touch Panels

manufactured by M2I Corporation

(Address:M2I Bldg,35-11,Jeonpa-ro 24beon-gil,Manan-Gu,Anyang-Si,Gyeonggi-Do,Korea)

which model is

TOPRX1500XD-Ex; TOPRX1200XD-Ex;  
TOPRX1200SD-Ex; TOPRX1000SD-Ex;  
TOPRX1000VD-Ex

Ex marking

Ex nA II C T6 Gc

product standard /

drawing number RX15N-A1000; RX12N-A2000; RX10N-A1000

has been inspected and certified by NEPSI, and that it conforms  
to GB 3836.1-2010,GB 3836.8-2014

This Approval shall remain in force until 2022.10.10

### Remarks

- 1.Conditions for safe use are specified in the attachment to this certificate.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment to this certificate.
- 3.Safe parameters specified in the attachment to this certificate.

Director



National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation

Issued Date 2017.10.11

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road  
Shanghai 200233, China

<http://www.nepsi.org.cn>  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

Tel: +86 21 64368180  
Fax: +86 21 64844580